

- LOCATE VAULT AS DIRECTED BY C.O.B. ELECTRIC UTILITY.
- 2. INSTALL GROUNDING PER C.O.B. STANDARD DRAWING #600-21.
- 3. INSTALL A MINIMUM 8" OF 3/4" CRUSHED ROCK UNDER VAULT.
- 4. ALLOW UP TO 3" OF EXTRA EXCAVATION DEPTH FOR ADJUSTING LID TO FINAL GRADE.
- 5. PROVIDE UNOBSTRUCTED SPACE CLEARANCES AROUND VAULT PER SD #600-72.

REF: 3315.1



REVISED: 08/13/2019

APPROVED:

STANDARD DRAWINGS

CONCRETE VAULT COVER, 48"x78"

SD

600-53