


NOTES:

1. LOCATE VAULT AS DIRECTED BY C.O.B. ELECTRIC UTILITY.
2. INSTALL GROUNDING PER C.O.B. STANDARD DRAWING #600-21.
3. INSTALL A MINIMUM 8" OF 3/4" CRUSHED ROCK UNDER VAULT.
4. ALLOW UP TO 3" OF EXTRA EXCAVATION DEPTH FOR ADJUSTING LID TO FINAL GRADE.
5. PROVIDE UNOBSTRUCTED SPACE CLEARANCES AROUND VAULT PER SD #600-72.
6. COAT INTERIOR WALLS, FLOOR, AND CEILING WITH WHITE LATEX PAINT.

APPROXIMATE WEIGHTS:  
12" SPECIAL EXT. SECTION - 2,175 LBS.  
24" EXTENSION SECTION - 4,350 LBS.  
72" BASE ENCLOSURE - 15,150 LBS.

REF: 3316.2



REVISED: 09/14/2021

APPROVED: *Beth Kofix*

STANDARD DRAWINGS

CONCRETE VAULT BASE, 60"x102"

SD

600-56