

SERVICE PANEL COVER

INSIDE SERVICE PANEL



DIRECTORY PLAQUE
(SEE C.O.B. STANDARD
DRAWING #600-93)

DUAL POWER SUPPLY
SMALL WIND SYSTEM

SMALL WIND
CIRCUIT BREAKER

WARNING
ELECTRIC SHOCK HAZARD
DO NOT TOUCH TERMINALS

TERMINALS ON BOTH LINE
AND LOAD SIDES MAY BE
ENERGIZED IN THE OPEN POSITION.

WARNING LABEL SHALL BE
NEXT TO OR JUST BELOW THE
SMALL WIND CIRCUIT BREAKER

PLACE THIS LABEL ON THE
SERVICE PANEL COVER
ALONG WITH THE
DIRECTORY PLAQUE

NOTES:

1. LABELS SHALL BE PLACED IN CLEAR VIEW ON ELECTRICAL EQUIPMENT WITHOUT COVERING MANUFACTURER LABELING.
2. PLAQUES SIZE SHALL NOT BE SMALLER THAN 2"X5" AND NO LARGER THAN 3"X6". (WITH EXCEPTION OF THE DIRECTORY PLAQUE)
3. FONT STYLE SHALL BE ARIAL AND FONT SIZE SHALL NOT BE SMALLER THAN SIZE 12 AND NO LARGER THAN SIZE 28.
4. PLAQUES SHALL BE RED WITH WHITE LETTERING.
5. SIGNS SHOULD BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT. ALL PLAQUES SHALL BE PERMANENTLY ATTACHED TO SURFACE OF ELECTRICAL EQUIPMENT BY MEANS OF EPOXY, SCREWS, OR RIVETS. OUTDOOR SIGNS SHALL BE EITHER METAL OR PLASTIC WITH ENGRAVED OR MACHINE-PRINTED LETTERS.

REVISED: 04/28/2011

APPROVED: *REB* /11-7-11

STANDARD DRAWINGS



SMALL WIND SERVICE PANEL WARNING LABELS

SD

600-92