



NOTES:

1. PER NEC ARTICLE 694.56, A PLAQUE SHALL BE INSTALLED AT OR ADJACENT TO THE TURBINE LOCATION PROVIDING BASIC INSTRUCTIONS FOR DISABLING THE SMALL WIND TURBINE.
2. LABELS LISTED ABOVE WITH PARENTHESES INDICATE THAT THE SPECIFIC NAME MUST BE INSERTED IN PLACE OF THOSE GENERAL TERMS.
3. DIRECTORY PLAQUE MUST BE PLACED ON THE SERVICE PANEL IN CLEAR VIEW WITHOUT COVERING MANUFACTURER LABELING.
4. DIRECTORY PLAQUE MUST BE UNIQUE TO EACH HOUSE IT REPRESENTS (I.E. ROOF LAYOUT, EQUIPMENT LOCATION, ETC.)
5. FONT STYLE SHALL BE ARIAL AND FONT SIZE SHALL NOT BE SMALLER THAN SIZE 12 AND NO LARGER THAN SIZE 28.
6. PLAQUES SHALL BE RED WITH WHITE LETTERING.
7. SIGNS SHOULD BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT. ALL PLAQUES SHALL BE PERMANENTLY ATTACHED TO SURFACE OF ELECTRICAL EQUIPMENT BY MEANS OF EPOXY, SCREWS, OR RIVETS. OUTDOOR SIGNS SHALL BE EITHER METAL OR PLASTIC WITH ENGRAVED OR MACHINE PRINTED LETTERS.

REVISED: 04/27/2011

APPROVED:

STANDARD DRAWINGS



SMALL WIND DIRECTORY PLAQUE

SD

600-93